



No: 1522-TNXX

Page: 1/ 20



MEASUREMENT & TESTING CERTIFICATE

Object : **Power Transformer**

Number of phase: 3

Model : Oil Immersed Serial No : 244736-01

Manufacture: Dong Anh Electrical Equipment Corporation-Joint Stock Company

Specification :

Rated Power (MVA) : 70 / 70

Rated Voltage (kV): 132 + 7 x 1.75% - 9 x 1.75% / 33

Rated Current (A): 306.2 / 1224.4

Connection: YNyn12

In accordance with: TCVN 6306-1:2015; TCVN 6306-2,3:2006
(IEC 60076-1,2:2011; IEC 60076-3:2018
IEC 60076-10; IEC60296; IEC60270)
Purchaser requirements

Results: See next page

Tested at: Laboratory **VILAS 1192**
Dong Anh Electrical Equipment Corporation-Joint Stock Company.

22nd May 2025

Date of issue

Q.C Department

Tran Ba Son

Vice general Director

Nguyen Hai Quan

The items (*) have been accredited by VILAS