



DONG ANH ELECTRICAL EQUIPMENT CORPORATION
Add.: No. 189 LamTien road, Thu Lam Commune, HaNoi, Viet Nam
Tel: (+84-24) 39686831 Fax: (+84-24) 38833113
Website: www.eemc.com.vn E-mail: mail@eemc.com.vn

No: 1842



MEASUREMENT & TESTING CERTIFICATE

Object: Power Transformer

Number of phase: 3 phase

Bushing: Ceramic

Model: Oil-immersed transformers

Serial No: 261314K-02

Manufacture: Dong Anh Electrical Equipment Corporation-Joint Stock Company

Rated Power (kVA): 500

Rated Voltage (kV) HV: $33 \pm 2 \times 2.5\%$

LV: 0.4

Rated current (A) HV: 8.7

LV: 721.7

Vector group: Dyn11

In accordance with:

- TCVN: 6306-1: 2015; TCVN 6306-3: 2006

TCVN 6306-3: 2006

- IEC 60076- 1: 2011; IEC 60076- 2: 2011;

IEC 60076-3: 2018

Transformer tested at: Vilas 1192 testing room - Dong Anh Electrical Equipment Corporation

February 7th 2026

QC Department

Lại Đăng Khoa

Vice general Director



Nguyen Hai Quan